

**PROHIBITION NOTICE**  
**URGENT - ACTION REQUIRED**  
**REGULATORY REFORM (FIRE SAFETY) ORDER 2005: ARTICLE 31**



Responsible Person	George Grant
Address of Responsible Person	Shindigger Craft Ltd, 6 Cross Key Street, Manchester, M4 5ET
Premises this Notice relates to	Shindigger Craft Ltd, 6 Cross Key Street, Manchester, M4 5ET

I Station Manager L Smart, on behalf of The Greater Manchester Combined Authority being the Fire and Rescue Authority for Greater Manchester, am of the opinion that use of the premises to which this notice relates involves a risk to relevant persons so serious that use of the premises ought to be restricted.

The use of premises which gives rise to the risk	<i>Public Bar</i>
The matters which give rise to the risk*	<i>Inadequate means of escape</i>
The use of the premises is restricted to the following extent	<i>The bar area is restricted to a maximum of 60 people</i> <b>Until the matters specified have been remedied</b>
The measures which must be taken to remedy the matters are	Provide adequate means of escape.

NOTE: The items listed above are the minimum steps to be taken in order for the Prohibition Notice to be withdrawn or varied. There may be other ways of remedying these matters. This Notice should not be considered to deal with all matters that may require attention

The Authority is of the opinion that the risk of serious personal injury is imminent and the Notice is to take effect **immediately**.

The Notice is to take effect from 25<sup>th</sup> October 2017 at 15.30 hrs

Signed



Dated: 25<sup>th</sup> October 2017

Being a person authorised in accordance with Section 101 of the Local Government Act 1972 to issue such a Notice.

**NOTES TO ACCOMPANY PROHIBITION NOTICE**